

利佳興業股份有限公司 RICH ELECTRIC CO.,LTD.

INVERTEK®

SWITCH-MODE BATTERY CHARGER (MICROPROCESSOR SYSTEM)



USER MANUAL

FOR ALL PATTERNS 1 OUTPUT





CONTENTS

Introduction	2
Technical Features	2
Advanced Charging Technique	
Safety Devices	
Options	4
Safety Instruction	4
Installation	5
Front Panel	6
LED Indicators	7
Instruction of Charging Curve Selection	7
DC Power Supply	9
BTS/Remote Control	9
Trouble Shooting Guide	
Specification	

Introduction

Invertek Battery Charger is small and lightweight charger that offers charging patterns which are perfectly adapted to each battery technology (liquid electrolyte, gel electrolyte, lead calcium, etc...). A charging pattern may be factory set to suit your specific application. To prolong the life of your batteries and conserve their initial capacity, the charger is programmed with 5 three-state charging patterns:

- **BOOST Charge/FAST Charge** :Restores battery capacity until 80 % in a short space of time.
- ABSORPTION Charge/BALANCE Charge : Complements of charge until 100 % of battery capacity
- **FLOATING Charge/TOP-UP Charge :** Compensates for constant battery drain, while keeping the battery fully charged.

Invertek Battery Charger is the only charger on the market to allow the battery to be connected and used constantly, while still offering a real BOOST (high voltage) charge over short period. The charger switches back to top-up mode automatically.

In accordance with EC standards, the Invertek Battery charger is fitted with a PFC (Power Factor Corrector) which limit peak current draw from the input power required from the generator or Mains supply to be reduced.

Technical Features

- Management and control by microprocessor
- Charging curve of 3 states IUU type
- Input voltage $230V \sim +10\%/-15\%$
- Frequency 50/60Hz
- Output voltage Ubat ±1%; output current Ibat ±5%
- Operating temperature -10 to + 45° C; storage temperature -20 to + 70° C
- Charging curve selection by rotate switch for 5 different batteries types
- Sensor used to balance charging voltage according to temperature gaps (-27mV/°C)
- Automatic air vented cooling
- Protection Index IP 235

Advanced Charging Technique

Charging curves of the 3-state IUU type, with a boost phase and a floating phase. The 3-state charging characteristic, used on boats everywhere, saves on charging time. In addition, the charger can be adapted to all types of battery thanks to its 5 integral charging curves supervised by a micro controller. Charge cycle starts on with the mains power-up of product.

BOOST/Fast Charge

Charging continues at constant current (charger Inom) until the battery reaches the maximum boost voltage. This voltage is maintained until the charging current falls to Inom/8 ~Inom/10 boost charge over short period (12 hours) from the mains power-up of product. This phase makes it possible to supply the maximum amount of energy in the least possible time.

FLOATING/Top-Up Charge

The charger supplies just the current necessary to keep the battery at a constant and stable voltage (floating voltage). This charging mode allows 12-volt equipment to be used continuously (water pump, refrigeration, auto pilot, radio, lights, etc.) without the batteries discharging.

It means that the on-board circuit can be used while keeping the battery charge level constant. WITHOUT BATTERY AND IN SPECIAL CIRCUMSTANCES, THE INVERTEK CHARGER SUPPLIES STABLE VOLTAGE.

General form of the charging curve (five possible levels according to battery type)



Charging Current

The nominal current shown in case of nominal voltage is the mean current supplied by the charger.

Safety Devices

Electronic protection against:

- Output short-circuits
- Battery discharge in the event of mains failure

Disjonction protection against:

- Battery overvoltage or undervoltage
- Battery or charger overtemperature
- **Protection by fuses against :**
- Mains input overload
- Battery polarity inversion

Anti-corrosion

Casing in aluminum with anti-corrosion paint.

Anti-impact

Resistance to impacts in normal use thanks to the 1.8 mm-thick casing (1,5mm for the cover).

Ventilation

If the internal charger sensor exceeds 45°C, the fan starts. If the internal charger sensor decreases to 40°C, the fan stops.

Options

1. Battery Temperature Sensor (BTS):

Sensor is used to balance charging voltage according to temperature gaps, compared with reference temperature 25°C. If temperature exceeds 45°C, pre-alarm starts and LED of BTS OH flashes. If temperature exceeds 50°C, charging stops and BTS OH is lit on. Charging restarts when temperature is less than 50°C.

Procedure of connecting BTS is:

- 1. Disconnect the charger from the mains (MANDATORY). To avoid short-circuit, disconnect the batteries.
- 2. Extract fixing screw from wires cover and remove it
- 3. Connect the sensor connector to the green terminal on the PCB. (See figure A)
- 4. Connect charger to the mains
- 5. Fix the temperature sensor(s) on corresponding battery(ies) with double-sided adhesive tape supplied with sensor.

To disconnect sensor from the charger, charger must be disconnected from the mains before (even if the charger indicates a default).

- **CAUTION:** In case of fault, charger switches off automatically. Disconnect charger from mains then wait for approximately 10 minutes before starting it again.
- 2. **Remote Control:** It can be connected to the Invertek charger. All operating controls and displays are available on the remote control unit.

Safety Instruction

A battery can generate gas in the case of high overcharge, that can be explosive. Attention must be paid to produce no spark or flame near a battery on charge, arrange for a well-ventilated room.

Invertek charger limits overcharges and reduces this risk.

• Excessive discharges are among the principal causes of premature wear. Invertek charger prevents such excessive discharge. After every discharge, (especially higher than 50%), recharging should not be deferred for a long time.

- Low and permanent overcharge is another cause of premature wear. The Invertek Charger delivers the current necessary for battery charge and adapts itself to supply the optimum end of charge.
- The accidental and violent overcharge or higher end of charge current produces early destruction by excessive rise of temperature. The temperature should not exceed 50°C. By the regulation of the current, the Invertek protects the battery from the temperature rise at the end of charge.

It is advisable to

- Put batteries in a well ventilated area
- Not to smoke near batteries
- Take the battery manufacturer prescriptions into consideration

Accidental Leakage Current between Line And Earth

- Connections will be realized by an electrician or a professional installer.
- The charger must be connected to a system having a two-pole differential circuit breaker with 30 mA sensitivity.

Accidental Leakage Current between Charge Circuit and Earth

- To detect accidental leakage currents to earth, you must use a safety device outside the charger.
- The rating and nature of the protection must be ensured by the installer.
- Special precautions are recommended on any installation where there is a danger of electrolytic effects.
- Regulations require the presence of a battery cut-out on the output + pole and on the output pole.

Precautions Regarding Lightning Strike

In geographic zones exposed to a high risk of lightning strikes, it may be recommended fitting a lightning conductor on the inlet side of the charger. **Rich Electric will not take charge of damaged caused by lightning strike.**

Precautions Regarding Electromagnetic Interference

- Make sure the length of the cables and screening connections are kept as short as possible.
- Separate the power supply cables from output cables.
- Cables must only carry the charger power supply. Branch or bridging connections in order to supply another equipment are too be banned.

Installation

The location of the Invertek charger must be chosen by the following criteria:

Protection from unauthorized handling.

Dry dust free room, no condensation, no rodents.

Keep ventilation holes free. The ventilation of the Invertek is designed in such a way that it will work most efficiently when mounted horizontally.

Before any connection, put the switch on the right charging curve.

- 1. Connect the positive battery on terminal marker +BAT and open the entry of the upper case to tighten it with screws.
- 2. Connect the negative battery cable to terminal marker –BAT and open the entry of the upper case to tighten it with screws.

Battery fuse board:

Model No.	12V/20A	12V/60A
FUSE Atofuse (car)	1 x 25A	2 x 30A
Model No.	24V/15A	24V/50A
FUSE Atofuse (car)	1 x 15A	2 x 30A

WARNING: Check carefully the tightness of the battery connections to the charger (risk if not properly tightened). **Rich Electric will not take charge of damage caused by a bad tightness of connections.**

Don't connect a charge distributor on an Invertek charger, 1 output.

- 3. Put the AC power cord in the rear panel. The charger operates on sector 90V to 250 VAC 50/60 Hz.
- 4. Conductor section according to charge current cables length is as follows.

Length	5m	10)m	1	5m	Sector flex s	section (5m)	Puissance
Current	5111	10	/111	1.	5111	220V	110V	(W)
30A	6 mm^2	10	mm^2	16	mm^2	1.5 mm^2	2.5 mm^2	750
40A	10 mm^2	16	mm^2	25	mm^2	1.5 mm^2	1.5 mm^2	500
50A	16 mm^2	25	mm^2	35	mm^2	1.5 mm^2	2.5 mm^2	1200
60A	25 mm^2	25	mm^2	35	mm^2	1.5 mm^2	2.5 mm^2	750

Main fuse board:

Model No.	12V/20A, 12V/60A, 24V/15A, 24V/50A
Temporized glass fuse 6.3x32mm	16A

Front Panel



LED Indicators

POWER: It is lit when the AC power has been input through the AC plug.
BOOST: It is lit as long as the battery is not fully charged at set charge current.
ABSORPTION: It is lit as long as the battery is not fully charged at set voltage.
FLOATING: It is lit when the battery is fully charged.
UV/OV:
Under Voltage---Deep battery discharge Ubat < 10V for 12V system and < 20V for 24V system. If Ubat stays < 10V for 12V system and < 20V for 24 system

- during more than 5 minutes, charger shuts down. To restart the charger: disconnect the mains, wait few minutes and reconnect the charger on mains.
- Over Voltage--- Battery overcharge Ubat > 16V for 12V system and > 32V for 24V system. If Ubat > 16V for 12V system and > 32V for 24V system during more than 5 minutes, charger shuts down. To restart the charger: disconnect the mains, wait few minutes and reconnect the charger on mains.
- **OH:** Over Heat---It is flashing when the heatsink of the charger reaches > 70 . The charger shuts down when the charger is > 80.

BTS OH: Battery Temperature Sensor Over Heat--- It is flashing when the BTS reaches > 45 . The charger shuts down when the battery temperature is > 50 .

FUSE OPEN: Fuse is broken.

Instruction of Charging Curve Selection (4 Battery Types and 1 User Define)

Every battery is designed according to particular technology and therefore calls for a particular charging curve.

With Invertek battery charger, you can achieve this perfect match between battery and charger using a switch, which is simply positioned according to the required, charging curve.

Note: Do indicate the type of your battery when buying the charger, and position the switch correctly before use.

The user can very easily adapt the Invertek charger to the type of battery by rotate switch used.

To modify configuration, carryout the following steps:

- STEP 1: Disconnect charger from the mains. To avoid short-circuit, disconnect the batteries.
- STEP 2: According to 4 different battery types and desired charge current (30%, 70% and 100%), choose the rotate switch from 1 to C. If the used battery is not in 4 listed battery types, User Define is available.

BATTERY TYPE	U Boost	U Float	Charge Current	Rotate Switch
	14.4V	13.5V	100%	1
Standard lead acid unsealed	14.4V	13.5V	70%	2
	14.4V	13.5V	30%	3
	14.2V	13.8V	100%	4
Sealed lead acid (Gel Cell)	14.2V	13.8V	70%	5
	14.2V	13.8V	30%	6
L and an lainm	14.6V	14.0V	100%	7
(Standard charge)	14.6V	14.0V	70%	8
(Standard charge)	14.6V	14.0V	30%	9
L and an lainm	16.0V	13.8V	100%	А
(Deep charge) *1	16.0V	13.8V	70%	В
(Deep charge) +1	16.0V	13.8V	30%	С
	—	—	100%	D
User Define *2	_	—	70%	Е
	_	—	30%	F

*1 This curve is used to regenerate the battery electrolyte in case of deep discharge (U Boost 16V), it is indispensable to disconnect the battery from other consumers.

*2 User Define: Use the switches of the BOOST VOLTAGE and FLOAT VOLTAGE to choose desired voltages from the following tables.

BOOST VOLTAGE Selection

Rotate	Boost	Rotate	Boost	Rotate	Boost	Rotate	Boost
Switch	Volt.	Switch	Volt.	Switch	Volt.	Switch	Volt.
0	14.4V	5	14.9V	Α	15.4V	F	14.3V
1	14.5V	6	15.0V	В	15.6V		
2	14.6V	7	15.1V	С	15.8V		
3	14.7V	8	15.2V	D	16.0V		
4	14.8V	9	15.3V	Е	14.2V]	

FLOAT VOLTAGE Selection

Rotate Switch	Floating Volt.	Rotate Switch	Floating Volt.
0	13.5V	5	14.0V
1	13.6V	6	13.1V
2	13.7V	7	13.2V
3	13.8V	8	13.3V
4	13.9V	9	13.4V

STEP 3: Connect charger to the mains.

Example:

To use the Invertek charger of 12V/60A to charge a battery of Sealed lead acid at desired

charging current 42A, users should choose rotate switch of battery type to be "5".

DC Power Supply

Invertek charger can not only charge the battery but also supply DC power directly. The desired voltage can be set by the following steps.

STEP 1: Choose the rotate switch of BATTERY TYPE to be "0".

STEP 2: Use the rotate switch (0~F) of BOOST VOLTAGE to set the first two digits of desired voltage. Refer to the below table for what 0~F represents.

Rotate	Boost	Rotate	Boost	Rotate	Boost	Rotate	Boost
Switch	Volt.	Switch	Volt.	Switch	Volt.	Switch	Volt.
0	13.0V	5	16.0V	Α	16.0V	F	16.0V
1	14.0V	6	16.0V	В	16.0V		
2	15.0V	7	16.0V	C	16.0V		
3	16.0V	8	16.0V	D	16.0V		
4	16.0V	9	16.0V	Е	16.0V		

STEP 3: Use the rotate switch (0~9) of FLOAT VOLTAGE to set the decimal of desired voltage. Refer to the below table for what 0~9 represents.

Rotate Switch	Floating Volt.	Rotate Switch	Floating Volt.
0	0.0V	5	0.5V
1	0.1V	6	0.6V
2	0.2V	7	0.7V
3	0.3V	8	0.8V
4	0.4V	9	0.9V

Example:

To set the desired DC power supply of 14.3V, firstly, choose the rotate switch of BATTERY TYPE to be "0" and then choose the rotate switch of BOOST VOLTAGE to be "1"; finally, choose the rotate switch of FLOAT VOLTAGE to be "3".

BTS/Remote Control

It is a port for phone jack of the battery temperature sensor and upcoming remote control to be connected.

Troubleshooting Guide

Problem and Symptoms	Possible Cause	Solution	
No output voltage and/or	No alternative current or main fuse is melted down	Check the fuse and replace it	
intensity	Main or generating unit too weak	Check the input voltage	
Intensity of charge is too	Battery is almost totally charged	Check that the charger is on a floating mode	
weak and less than 1078	Alimentation is too weak	Check the input voltage	
Charger delivers a weak	Battery consumption > power of the charger	Reduce the consumption on the battery	
intensity	One or several elements of the battery present a short-circuit	Check that there 's no increase of battery temperature	
	Loss (emission of gas)	Change the battery or check the level of water	
Battery is quickly empty	Sulfate on / stagnation	Charge / discharge several time the battery or check the charging curve or replace the battery	
	Consumption on the battery during the charge is too important	Decrease the consumption	
charged	Time of charge is too short	Choose a more powerful charger	
	Battery temperature too weak	Use a temperature sensor	
	Defective battery	Change the battery	
	Defective battery	Replace the battery	
Battery is hot/emission of gas	Temperature of the battery is too high	Use a temperature sensor and/or check the charging curve	
UV/OV LED ON	Stop because of battery voltage < 10 V for 12V or battery voltage > 16V (< 20V/> 32V for a 24V battery)	Disconnect the charger, wait 20 minutes and connect to the main	
OH LED flashes or ON	The charger is near to the "switch off" temperature	Ventilate the charger	
BTS OH LED flashes or ON	Battery temperature is too high (with a temperature sensor)	Check the charging curve and placed the battery in a ventilated area	

Problem and Symptoms	Possible Cause	Solution	
	Default of the battery which is	Check the connection of the	
Fuse open LED ON	in deep discharged or polarity	battery, the polarity and	
	inversion of the battery	the output fuse	
No LED is lighting when		Check the main input, the	
the charger is connected to	DEFAULT	connection of display and	
the mains		the fuses.	

Specifications

Output: 12V					
Model No.	ADC-20X-1	22	A	DC-60X-122	
Input Voltage	Input voltage 230V ~ +10%/-15%				
Output Voltage	12V				
Charging Capacity	20A 60A				
Frequency		50Hz/	60Hz		
Output Patterns		1 o	r 3		
Input Voltage U bat		+/-2	2%		
Output Current I bat		+/-1	0%		
Charging Curve Type		3 states I	UU type		
	(Boost Charge, Absorption Charge, Floating Charge)				
	By SWITCH for 5 different battery types:				
Charging Curve Selection	Standard lead acid unsealed, Sealed lead acid (Gel Cell),				
	Lead calcium (standard charge/deep discharge), User define				
Working Temperature		-10 ~	+45		
Storage Temperature		-20 ~	+70		
Dustantian Fasture	Against output short-circuit, battery discharge in the event of				
r rotection reature	mains failure, mains input overload, battery polarity				
Protection Options	Battery or charger overtemperature				
	(Temperature sensor)				
Dimensions	310x200x70 mm	400x250	x80mm	400x250x80 mm	
Weight	3 kgs	6 k	gs	6 kgs	

Output: 24V			
Model No.	ADC-15X-	242 A	DC-50X-242
Input Voltage	Input voltage 230V ~ +10%/-15%		
Output Voltage	24V		
Charging Capacity	15A		50A
Frequency	50Hz/60Hz		
Output Patterns	1 or 3		
Input Voltage U bat	+/-2%		
Output Current I bat	+/-10%		
Charging Curve Type	3 states IUU type		
	(Boost Charge, Absorption Charge, Floating Charge)		
Charging Curve Selection	By SWITCH for 5 different battery types:		
	Standard lead acid unsealed, Sealed lead acid (Gel Cell), Lead		
	calcium (standard charge/deep discharge), User define		
Working Temperature	$-10 \sim +45$		
Storage Temperature	-20 ~+70		
Protection Feature	Against output short-circuit, battery discharge in the event of		
	mains failure, mains input overload, battery polarity inversion		
Protection Options	Battery or charger overtemperature		
	(Battery Temperature Sensor)		
Dimensions	310x200x70 mm	400x250x80mm	400x250x80 mm
Weight	3 kgs	6 kgs	6 kgs

